

## Simulation Diagnostics | Hacking Simulation CIBSE simulation Group

Annie Marston Ph.D., BEMP, LEED AP | 20th March 2018



Don't Compromise -- Simulate




Ph.D. in Renewable Energy and Architecture

Worked on mostly American and German buildings

Simulation Specialist

Over 10 years of experience




My work Includes:


- Over 75 LEED projects (8 Platinum)
- 2 net zero buildings
- Research projects for American government
- 10 IEMPs
- CFD studies, thermal comfort studies, daylighting studies, optimization studies.

## About Me


# Services



Energy modelling for LEED



Complex HVAC and controls




IEMP and community co-ops




Teaching and online courses


# Simulation beyond certification and compliance




Automatic Energy Model



Post Occupancy Controls



Integrated Energy Master Plans




OD for Energy Models

# About Sim<sup>2</sup>

PROBLEM 1: Inputting data into a simulation engine GUI takes lots of time, is complicated and prone to errors

PROBLEM 2: Input errors and misunderstanding outputs leads to poor results, lack of confidence in modelling and, at worse, incorrect analysis and advice to the client



“The first principle is you must not fool yourself – and you are the easiest person to fool” Richard Feynman\*

**LEED Points**

Energy Cost Savings	9.1%
Energy Use Intensity	215 (238) kWh/m <sup>2</sup> /a

**Building Summary**

Location and Climate		Building Details	
Location		Project Type	CI v4
Climatezone	4b	ASHRAE 90.1 Version	2007
Description	Mixed Dry	Number of Floors	8
Heating Degree Days	2642	Building footprint	134 m <sup>2</sup>
Cooling Degree Days	182	New Construction Floor Area	1,075 m <sup>2</sup>
Weather File	FRA_Paris_Orly.071490_IWE C.epw	Existing Building Floor area	1,075 m <sup>2</sup>

**3D Building Model**

**Building Envelope**

Construction Overview		Internal Gains	
Construction Overview	Concrete with curtain wall	Lighting	Design 5.9W/m <sup>2</sup> / Baseline 10.5W/m <sup>2</sup>
Window distribution	75%	People	7.7 m <sup>2</sup> /Per
Exterior Lighting	Baseline 0 kW / Design Case 25 kW	Equipment	29 W/m <sup>2</sup>
Infiltration	0.1 ACH	Service Hot Water	Electricity 0.93

**Summary of HVAC**


Zone Conditioning	fan coils, electric resistance heating and district cooling
Air Handling Units	MVHR - 49% heat recovery, electric resistance heating, water cooling coil from district cooling
Other	server room with DX cooling coil
Plant Information	District cooling and electric heating
Chiller COP	-
Heating Fuel Type	electricity

# Modelling Input Sheet






Scan the room



Data removal





Work with 2D data



Use algorithms to produce continuous floor plan




Use algorithms to create spaces (thermal zones)




Add lighting and equipment loads to the spaces



Add windows and window U-Value



Identify windows



Create distinct spaces (thermal zones) in 3D model

# Data Input - Geometry

AutoSave p002 Gilead Paris Floor4 - Input Spreadsheet submission 1 - Excel

File Home Insert Page Layout Formulas Data Review View Help Tell me what you want to do

Clipboard Font Alignment Number Styles Cells Editing

AK279

Design Case Construction (SI)											Baseline Case Construction (SI)																		
Roof - Gilead											Roof - Gilead																		
Name of Assembly	Roof with external insulation under sealing										Residential?	no	Code in documentation	ENERGYPLUS code	Name of Assembly	Roof (insulation Entirely Above Deck)										Residential?	no	Code in documentation	ENERGYPLUS code
Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
14.e	Outside Air Film									0.27 W/m <sup>2</sup> K			a.e	Outside Air Film										0.27 W/m <sup>2</sup> K					
15	1 Insulation	y	132	0.13	0.04	3	256	837	7.857	0.30		1	Rigid Insulation (baseline)	y	132	0.132	0.04	3.29	256	837	7838	0.30							
16	2 Concrete	n	230	0.23	0.62	0	2243	837	119.944	8.29		2	Concrete (baseline)	n	230	0.230	0.62	0.37	2243	837	119944	8.29							
25.g	Inside Air Film											d.i	Inside Air Film																
26	Thickness of the construction		0.36						U Value Assembly 0.273 W/m <sup>2</sup> K				Thickness of the construction		0.36 m						U Value Assembly 0.273 W/m <sup>2</sup> K								
27	R-value Insulation		3.30		19				Heat Capacity 128				R-value Insulation		3.29 m <sup>2</sup> /K/W						Heat Capacity 128								
84	Exterior Wall - Gilead Curtain wall											Exterior Wall - Gilead Curtain wall																	
Name of Assembly	Curtain wall (see glazing)										Residential?	no	Code in documentation	Name of Assembly	Walls, Above-Grade Steel-Framed										Residential?	no	Code in documentation		
Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
86.a.e	Outside Air Film									0.33 W/m <sup>2</sup> K			a.e	Outside Air Film										0.36 W/m <sup>2</sup> K					
87	1 Insulation	n	100	0.10	0.04	3	2243	837	52.150	0.40		1	Concrete (baseline)	n	100	0.100	0.620	0.16	256	837	5952	6.20							
88	2 Concrete	n	300	0.30	0.62	0	256	837	17.856	2.97		2	Cavity Wall Insulation (Bassy)	101	0.101	0.040	2.54	2243	837	52922	0.39								
89	3 Plaster Board	n	13	0.01	0.23	0.06	1800	800	5.200	17.69		3	Gypsum Board (Baseline)	n	13	0.013	0.230	0.06	1800	800	5200	17.69							
97.g	Inside Air Film											d.i	Inside Air Film																
98	Thickness of the construction		0.41						U Value Assembly 0.511 W/m <sup>2</sup> K				Thickness of the construction		0.21 m						U Value Assembly 0.563 W/m <sup>2</sup> K								
99	R-value Insulation		0.00		0				Heat Capacity 75				R-value Insulation		2.54 m <sup>2</sup> /K/W						Heat Capacity 64								
102	Exterior Wall - Gilead Concrete wall											Exterior Wall - Gilead Concrete wall																	
Name of Assembly	Concrete plans										Residential?	no	Code in documentation	Name of Assembly	Walls, Above-Grade Steel-Framed										Residential?	no	Code in documentation		
Layer	Material	Include in R-value insulation?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
104.e	Outside Air Film									0.33 W/m <sup>2</sup> K			a.e	Outside Air Film										0.36 W/m <sup>2</sup> K					
105	1 Concrete	n	300	0.30	0.62	0.48	2243	837	156.449	2.07		1	Concrete (baseline)	n	100	0.100	0.620	0.16	256	837	5952	6.20							
106	2 Insulation	n	100	0.10	0.04	2.50	256	837	5.952	0.40		2	Cavity Wall Insulation (Bassy)	101	0.101	0.040	2.54	2243	837	52922	0.39								
107	3 Plaster Board	n	13	0.01	0.23	0.06	1800	800	5.200	17.69		3	Gypsum Board (Baseline)	n	13	0.013	0.230	0.06	1800	800	5200	17.69							
115.g	Inside Air Film											d.i	Inside Air Film																
116	Thickness of the construction		0.41						U Value Assembly 0.511 W/m <sup>2</sup> K				Thickness of the construction		0.21 m						U Value Assembly 0.563 W/m <sup>2</sup> K								
117	R-value Insulation		0.00		0				Heat Capacity 168				R-value Insulation		2.54 m <sup>2</sup> /K/W						Heat Capacity 64								
191	Interior Wall - Gilead Concrete											Interior Wall - Gilead Concrete																	
Name of Assembly	Concrete										Residential?	No	Code in Documentation	Name of Assembly	Concrete										Residential?	No	Code in Documentation		
Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
194.e	Outside Air Film									3.10 W/m <sup>2</sup> K			a.e	Outside Air Film															
195	1 concrete	n	200	0.20	0.62	0.52	2243	837	104300	3.10		1	Concrete (Baseline)	n	200	0.2	0.62	0.52	2243	837	104300	3.10							
196	2											2																	
197	3											3																	
205.g	Inside Air Film											d.i	Inside Air Film																
206	Thickness of the construction		0.20						U Value Assembly 3.10 W/m <sup>2</sup> K				Thickness of the construction		0.20 m						U Value Assembly 3.10 W/m <sup>2</sup> K								
207	R-value Insulation		0.00		0				Heat Capacity 104				R-value Insulation		0.00 m <sup>2</sup> /K/W						Heat Capacity 104								
227	Below Grade Wall - Name in EnergyPlus											Below Grade Wall - Name in EnergyPlus																	
Name of Assembly	Concrete below grade wall not part of this model										Residential?	No	Code in documentation	Name of Assembly	Walls, Below-Grade										Residential?	No	Code in documentation		
Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
229	Outside Air Film									2.07 W/m <sup>2</sup> K			a.e	Outside Air Film															
231	1 concrete	n	300	0.30	0.62	0.484	2243	837	156449	2.07		1	1 CMU (Concrete Block) (baseline)	200	0.203	0.778	0.26	2300	837	390795	3.83								
232	2											2	Cavity Wall Insulation (bassy)	(10)	(0.010)	0.050	-0.21	256	837	(2.212)	-4.84								
277.g	Inside Air Film											d.i	Inside Air Film																
278	Thickness of the construction		0.60						U Value Assembly 5.88 W/m <sup>2</sup> K				Thickness of the construction		0.12 m						U Value Assembly 6.473 W/m <sup>2</sup> K								
279	R-value Insulation		0.00		0				Heat Capacity 156				R-value Insulation		0.00 m <sup>2</sup> /K/W						Heat Capacity 231								
281	Interior Floor - Gilead Concrete											Interior Floor - Gilead Concrete																	
Name of Assembly	Concrete										Residential?	No	Code in documentation	Name of Assembly	Interior Floors Steel-Joist										Residential?	No	Code in documentation		
Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)			Layer	Material	Count for R-value?	d [mm]	d [mm]	Conductivity (W/mK)	R-Value (m <sup>2</sup> W/K)	Density (kg/m <sup>3</sup> )	Specific Heat (J/kg K)	Heat Capacity (Wh/m <sup>2</sup> K)	U-Value (W/m <sup>2</sup> K)						
283	Outside Air Film									5.88 W/m <sup>2</sup> K			a.e	Inside Air Film															
284.e	Outside Air Film											d.i	Inside Air Film																
285	Thickness of the construction		0.17						U Value Assembly 5.88 W/m <sup>2</sup> K				Thickness of the construction		0.17 m						U Value Assembly 5.88 W/m <sup>2</sup> K								

Overview Check Sheet Climate Analysis Zoning Construction Details Constructions Internal Gains Schedules pOverview Ext. Light SHW OA ...

Ready


# Data Input – Envelope Constructions








# Translating a mechanical drawing to energy component drawings



Data Input – HVAC and Controls

# Translating a mechanical drawings to energy component drawings



## Data Input – HVAC and Controls

# Translating mechanical information to simple table to record inputs and generate mechanical system for simulation.

CTA 3  
Position des centrales : Superpostes

**1 CAISSON DE TRAITEMENT D'AIR TYPE CCM170**

Position : HORIZONTALE      Montage : INTERIEUR  
Orientation centrale : \* Accès : \* Raccord

Orientation soufflage ventilation :  
Suivant notice N° xx5JT

Double paroi ep. 50mm avec isolation laine minère  
Carrosserie extérieure peinte ou 2 axes - GREES (P.A.  
Présentation renforcée par un vernis structure.

Conformément à la norme EN 1886,  
- Résistance Mécanique : classe 2  
- Étanchéité : classe B  
- Transmittance Thermique : classe T3

**INTRODUCTION**

- Position : 1800  
- Dimension aspiration : 15x30  
- Débit d'air : 16405  
- Vitesse sortie d'air refroidissement : 112,4  
- Pression disponible / gainé : 379 P  
- Rendement ventilateur : 81 %  
- Puissance sur arbre ventilateur : 8,47 k  
- Vitesse de rotation ventilateur : 2054  
IAMATEUR, P=1 kW, N=100 Tr/min  
DPS - Classe F - PTD  
Tension TRI 400/230 Volts 50 Hz  
Rendement acoustique : 21,10  
Rendement de débrayage direct : 105,4  
Rendement de débrayage double triangle : 54,16  
- Puissance électrique absorbée : 19,94 k  
- MONTAGE MOTEUR : INTER  
- Avec plots antivibratoires  
- PORTE SUR CHARNIÈRES  
- BILLET SUR BISCAGE  
- BILLET ELECTRIQUE 240 CABLE RACCORDE SUR INT  
- INTERPRETES DE PRESSIONS CABLE ET MONTE, sans

**SECTION DE DETENTE**  
- Avec pannes ouvert

**FILTRE ODPS F8 (EXL8)** : 95% C  
- Montage en glissières galva  
- Avec prises de pression  
- MANOMÈTRE à TUBE INCLINE MONTE  
- PORTE SUR CHARNIÈRES

**REGISTRE**

SPECTRE DE PUISSANCE A				
FREQUENCES (Hz)	63	125	250	
Refroidement gainé centrale	88	86	91	87
Aspiration gainé centrale	82	81	88	84
Rezonance par le caisson	72	74	74	61

**NIVEAU DE PUISSANCE GLOBAL** : 4884 db(A) 85  
Refroidement gainé centrale : 95 88  
Aspiration gainé centrale : 91 85  
Rezonance par le caisson : 81 67 Tolens

**EXTRACTION**

de pression  
- MANOMÈTRE à TUBE INCLINE MONTE  
- PORTE SUR CHARNIÈRES

**SECTION DETENTE**  
- Avec pannes ouvert

**SECTION DE CHAUFFAGE ELECTRIQUE 1 RANG**  
Mise de 15 résistances branchées libérées à suite centrale et d'un thermostat de sécurité  
- Puissance installée : 82,5 kW  
- Nombre d'allures ainsi possible : 15 (à position à la commande)  
- Raccordement : TRI 400 V  
- T° entrée air / H° % : 15,7°C / 73 %  
- T° sortie air / H° % : 20,8°C / 12 %  
- Vitesse de passage d'air : 2,83 m/s  
- ECRAN ANTI-COINDEMENT  
- Avec pannes ouvert

NOTE : La notice descriptive ne doit pas être utilisée comme dispositif de protection antipol d'une batterie à eau.

**TIBOR POUR THERMOSTAT ANTIGEL**  
- THERMOSTAT MONTE

**SECTION ACCES**  
- Avec pannes ouvert

**SECTION BATTERIE 6 RANGS (REFRIGERATION)**  
- Pas : 2,5 mm  
- Pression de service : 8 bar  
- Pression d'épreuve : 20 bar  
- Tubes Cuivre / Aluinox Aluminium Ø12  
- Diamètre extérieur minimum : 120,00 kW  
- Puissance frigorifique :  
air :  
- Débit nominal : 16469 m³/h (4,57 m³/s)  
- Entrée air - T° / H° % / TD : 12,0°C / 60 % / 21,8 °C  
- Sortie air - T° / H° % / TD : 15,0°C / 94 % / 14,4 °C  
- Vitesse ventilateur : 2,96 m/s  
ILLUDE :  
- Eau :  
- Pression : 6,00 °C / 16,6 °C  
- Débit d'eau : 10,28 m³/h (0,002856 m³/s)  
- Pertes de charges sur eau : 27,403 kPa



Table 21 Specifications for proposed AHU

General Information						
AHU Nr.	System description	Areas that the system feeds	Max Air Flow rate	Min Air Flow rate	Outdoor Air Flow Rate	Exhaust Air Flow rate
CTA3	Dedicated outdoor air system	west side of the building offices	0.364	0.36	0.36	0.364
CTA4	Dedicated outdoor air system	east side of the building offices	0.666	0.67	0.67	0.67

Filter	Supply Fan				Return Fan				Heat Exchanger	
	Supply fan Pressure Drop	Fan Power Supply/Extract	Efficiency	Fresh Air/Fan Schedule	Filter	Return Fan Pressure Drop	Fan Power Supply/Extract	Efficiency	Type	Efficiency
F8	379	8.5 kW	81%	MVHR-CTA3 - Fresh Air Schedule	F5	592	6.2 kW	80%	Flat Plate	47%
F8	624	16.0 kW	81%	MVHR-CTA4 - Fresh Air Schedule	F5	782	11.8 kW	82%	Flat Plate	47%

AHU Nr.	Heating Coil			Cooling Coil					
	Heating Coil [kW]	Entering Air Temperature [°C]	Leaving Air Temperature [°C]	Cooling Coil Total [kW]	Water temp. in [°C]	Water temp. out [°C]	Flow Rate [m³/s]	Entering Air Temperature DB [°C]	Leaving Air Temperature DB [°C]
CTA3	82.5	5.7°C	20.8°C	120	6°C	16°C	4.57	32°C	15°C
CTA4	144	5.6°C	22.1°C	193	6°C	16°C	16.54	32°C	15°C

## Data Input – Automation Process



Translating mechanical information to simple table to record inputs and generate mechanical system for simulation.

Proposed Design						
Space Use	Zone Heating	Zone Cooling	Mechanical Ventilation	Connection to zone	Cooling Supply	Heat Supply
Office	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
OpenOffice	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
Storage	FanCoil	FanCoil			Water	Electric
Corridor	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
TeaRoom	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
MeetingRoom	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
CopyRoom	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
PhoneBooth	FanCoil	FanCoil	MVHR	SingleDuctUncontrolled	Water	Electric
Shower	FanCoil	FanCoil			Water	Electric
AV	FanCoil	FanCoil			Water	Electric

Fresh Air Calculation	Area	Number of people	Outdoor Air - ASHRAE 62.1 2010 Calculation					TOTAL	
			ASHRAE 62.1 Type	cfm /person	cfm/ft <sup>2</sup>	TOTAL cfm	No. Person		cfm/psf
Office	246.0	2,648	18 Office Building - office space	5.0	0.1	248.9	2.5	0.3	0.48
OpenOffice	431.3	4,642	66 Office Building - office space	5.0	0.1	608.5	2.5	0.3	0.68
Storage	53.3	573							
Corridor	173.1	1,841	General - Corridors		0.1	110.5		0.3	0.30
TeaRoom	30.7	330	2 Office Building - office space	5.0	0.1	29.8	2.5	0.3	0.46
MeetingRoom	101.8	1,096	44 General - Conference Meeting	5.0	0.1	285.7	2.5	0.3	1.38
CopyRoom	18.0	194	Office Building - office space	5.0	0.1	11.6	2.5	0.3	0.30
PhoneBooth	9.4	101	2 Office Building - Breakrooms	5.0	0.1	22.2	2.5	0.6	1.13
Shower	6.1	66							
AV	7.3	78	Office Building - office space	5.0	0.1	4.7	2.5	0.3	0.30

The image shows a Microsoft Excel spreadsheet titled "p002 Gilead Paris Floor 4 - Input Spreadsheet submission 1 - Excel". The spreadsheet contains detailed HVAC system data, including zone types, areas, volumes, exhaust rates, and flow rates from various units (AHU, FCU). A red arrow points to a specific row in the spreadsheet. Below the spreadsheet, a file explorer window is open, showing the path "SIM2 work > 002 Gilead Paris > 01 EnergyPlus Files > Automatic spreadsheets inputs". The file explorer lists several Excel files, including "01b p002 Gilead Paris Sciences - Zone Conditioning", "02 p002 Gilead Paris Sciences - Design Case AHUs", "99 p002 Gilead Paris Sciences - Baseline System 4 PSZ-HP", and "99 p002 Gilead Paris Sciences - Baseline System 8 with PFP boxes".

# Data Input – HVAC and Controls




Problem 1: Inputting data into a simulation engine GUI takes lots of time, is complicated and prone to errors

Solution 1: Excel GUI, utilize the power of excel and its formulas to record all inputs, do the necessary calculations, automatically generate simulation code and provide neat information for the client report. Use excel to QA your inputs


*Model*

*Control*

“If you can’t ~~draw~~ it, you can’t ~~build~~ it”





Operation Pattern




Trend data visualization


# Operation Diagnostics - Commissioning



Chiller Operation Annually




Flow through the Economizer Annually




# Simulation Diagnostics





# Output Data – Scripting Process



# Output Data – Scripting Process

#### 4.11.1.2 Fans and Pumps

The fan power calculation for the baseline building design is based on G3.1.2.9 of ASHRAE Standard 90.1 2010 Appendix G and 6.5.3.1 of ASHRAE Standard 90.1 2010. The fan supply volume was calculated using 20°F difference between the supply air and the room air temperature according to G3.1.2.8.

The minimum outdoor air flow into each zone is identical to the outdoor air flow for the design case. The minimum outdoor air flow into the zones in the baseline case will never drop below that required for the design case. The peak fan power supply flow was calculated for the baseline case using Table G3.1.2.10 – System 3 through 8:

$$\text{Fan power} = \text{bhp} \times 746 / \text{fan motor efficiency}$$

**Table 18 Baseline Appendix G Fan Power Calculations**

				Baseline FanPower										
				11.8 kW										
				Baseline outdoor air flow rate	1.03 m³/s									
				Baseline total flow rate	5.21 m³/s									
Fan Name	Variable / Constant	AHU or Terminal Box?	Supply/ Return/ Exhaust (AHU) / unconditioned (exhaust fan)	Outdoor Air Flow rate [m³/s]	Peak flow rate [m³/s]	flow rate [l/s]	Electricity required for the fan P <sub>Fan</sub> [W]	bHP	Motor Efficiency	cfm	Pressure Drop	BASELINE system	Fan Efficiency	
<b>BASELINE</b>				<b>1.0</b>	<b>5.2</b>	<b>11848</b>	<b>11044</b>							
AHU04	Variable	AHU	Supply	0.9	5.0	4971	11414	13.7	89.5%	10,534	1,492	8	0.65	
04 Corridor1	Constant	AHU	Supply	0.0	0.0	8	14	0.0	82.5%	17	1,171	4	0.65	
04 Corridor2	Constant	AHU	Supply	0.0	0.1	73	131	0.1	82.5%	154	1,171	4	0.65	
04 Corridor3	Constant	AHU	Supply	0.1	0.1	82	148	0.2	82.5%	174	1,171	4	0.65	
04 Corridor4	Constant	AHU	Supply	0.0	0.0	11	20	0.0	82.5%	23	1,171	4	0.65	
04 Storage3	Constant	AHU	Supply	0.0	0.0	11	19	0.0	82.5%	23	1,171	4	0.65	
04 TeaRoom	Constant	AHU	Supply	0.0	0.1	56	101	0.1	82.5%	119	1,171	4	0.65	

Fan calculations from the modelling input master file

The fans were modelled with a night cycle which was put on during unoccupied times. The fans cycle on and off during this time when temperature of the space is required to be met. An analysis of the fan operation in the model is detailed below:

- The total number of hours the fan is operating for is 4088
- The total number of hours the fan is operating during unoccupied times is 87
- The peak fan power is 5.9kW

Operating hours during occupied and unoccupied times and peak fan power, all automatically generated from the output file

## Output Data – Night Cycle Analysis Project Example




Figure 19 Night Cycle Analysis for the Baseline Fan (unoccupied times)

The green line represents the setback temperatures during unoccupied times and the maximum flow rate of the system. The grey dotted line represents the minimum air flow rate during occupied times. During unoccupied times the night cycle comes on to maintain the setback temperatures and is between 0 kg/s and 1.97kg/s flow rate.

Automatically generated from outputs, showing that the fans are cycling on and off at night to maintain temperature




Figure 20 Occupied Times Baseline Fan Analysis

The graph above shows the fan operation during occupied times. The orange dots represent the flow rate and the minimum zone temperature fed by the AHU. The fan operation is always above the minimum flow rate of 1.97 kg/s and ramps up during the cooling season. The dots fall below the set temperature of 20C as this includes zones which have a lower setpoint such as the corridors and storage rooms.

Automatically generated showing how the fan is operating during occupied hours and that the zone is reaching temperature during those times

## Output Data – Night Cycle Analysis Project Example

002 Gilead Paris - Baseline Diagnostics - Excel

MEETINGROOM-LIGHTING:Schedule Value [(Hourly)]

DO	DP	DQ	DR	DS	DT	DU	DV	DW	DX	DY	DZ	EA	EB	EC	ED	EE	EF	EG	EH	EI	EJ	EK	EL	EM	EN	EO	EP	EQ	
SERVER-EQUIPMENT	OFFICE-OCCUPANCY	MEETINGROOM-OCCUPANCY	LUNCHROOM-OCCUPANCY	OFFICE-LIGHTING	STORAGE-LIGHTING	SERVER-LIGHTING	MEETINGROOM-LIGHTING	LUNCHROOM-LIGHTING	HEATING-18-SETBACK	HEATING-14-SETBACK	COOLING-26-SETBACK	COOLING-50-SETBACK	COOLING-24-SETBACK	AHU1-FRESH-AIR-SCHEDULE	ZONE-CONTROL-TYPE	LUNCHROOM-FRESH-AIR-SCHEDULE	WATER-TANK-TEMPERATURE	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	HC-Heating Coil	
Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Value	Power	Power	Power	Power	Power	Power	Power	Power	Power	Power	Power	Power
[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[(Hourly)]	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)	[W](Hourly)
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.15754	78.0853	99.45652	198.4054	170.2711	729.9633	50.28946	735.4891	528.0673	68		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.29441	78.26794	99.97893	199.8205	171.362	737.0333	50.45919	744.6258	534.7717	65		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.43406	78.45648	98.75412	196.9962	169.0715	717.577	50.62827	706.2095	510.153	65		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.57948	78.65471	98.02029	195.3131	167.684	707.3762	50.79759	692.1494	500.6959	64		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.72665	78.85496	97.75267	194.7293	167.1717	700.9426	50.96636	679.0559	492.1672	64		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	53.87193	79.05155	97.65171	194.5426	166.9802	698.0006	51.13475	671.8473	487.2167	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.01144	79.23927	97.75827	194.8592	167.1982	699.431	51.30095	677.1714	490.3957	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.14368	79.41642	97.91902	195.3097	167.5327	699.4667	51.46412	678.2353	491.1263	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.27263	79.58904	98.10785	195.8291	167.9303	699.7332	51.6283	674.508	488.8802	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.39787	79.75687	98.2775	196.2976	168.2943	700.3081	51.79151	675.5376	489.2713	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.51829	79.91807	98.27998	196.361	168.3421	689.7852	51.95197	650.354	472.707	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.63322	80.0701	98.19028	196.2181	168.233	678.7871	52.11084	624.471	455.1542	63		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.73821	80.20293	98.0766	196.0722	168.1341	673.564	52.26831	617.1231	449.3364	57		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.8281	80.30585	97.98335	196.0702	168.1682	667.6893	52.42409	603.414	440.177	56		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.90227	80.37725	97.87242	196.136	168.2757	672.1439	52.57894	615.0252	447.4928	57		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	54.96315	80.4228	97.70347	196.1573	168.363	681.6738	52.73228	641.3848	464.7901	56		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.01731	80.45678	97.55715	196.3355	168.5809	689.6288	52.88393	658.7806	477.1762	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.07414	80.49935	97.55417	196.753	168.9822	694.8037	53.03384	668.7573	484.6576	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.14092	80.56602	97.52165	197.0915	169.3029	696.9124	53.18184	672.0089	487.5199	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.22058	80.66211	97.60792	197.6467	169.7746	699.9464	53.32899	677.1021	491.2343	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.31115	80.78307	97.79555	198.3839	170.3714	704.0623	53.47461	684.3192	496.1501	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.40999	80.92269	98.00014	199.1157	170.948	708.0953	53.61893	691.4178	500.9079	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.51456	81.07534	98.08825	199.5301	171.2596	708.5742	53.76162	690.3469	500.4519	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.62418	81.23876	98.04615	199.6021	171.2894	703.1524	53.90405	674.2677	490.3225	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.73669	81.40826	98.04839	199.7586	171.3811	706.1779	54.0459	683.7968	495.9406	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.84891	81.57755	98.28807	200.4757	171.9186	712.2614	54.18645	698.1156	504.9491	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	55.96045	81.74616	98.58175	201.3152	172.5544	716.8568	54.32647	706.2901	510.3155	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	56.07262	81.91731	98.91376	202.2305	173.2505	721.9201	54.46631	715.3134	516.2426	61		
0.75	0	0	0	0.05	0	0	0.05	0.05	18	14	26	50	24	0	4	0	0	56.18576	82.09193	99.57221	203.9067	174.5523	731.7763	54.60521	733.1658	527.9076	61		
0.75	0	0	0	0.1	0	0	0.1	0.05	18	14	26	50	24	0	4	0	0	56.30078	76.35136	95.55434	192.9852	165.8178	704.3552	49.9386	733.2608	521.5336	61		
0.75	0.1	0	0	0.1	0	0	0.1	0.05	20	16	24	50	24	0	4	0	0	60.498.7282	232.6085	257.8002	309.1186	260.3064	920.2537	672.3245	2824.421	349.4453	2135.971	1522.517	61
0.75	0.2	0	0.05	0.3	0.1	0.1	0.3	0.4	20	16	24	50	24	1	4	1	0	60.327.8129	145.8389	250.3847	309.1186	260.3064	807.6255	595.328	2444.116	311.4922	1612.302	1168.626	14
0.75	0.95	0	0.05	0.9	0.1	0.1	0.9	0.6	20	16	24	50	24	1	4	1	0	60.3.028487	186.67	163.7925	179.8117	632.5959	453.304	1910.449	245.3014	0	0	0	0
0.75	0.95	0	0.05	0.9	0.2	0.2	0.9	0.6	20	16	24	50	24	1	4	1	0	60.171.040	153.5628	163.635	518.0722	278.6176	1515.022	201.2024	0	0	0	0	0

Energyplus data APP G Sizing sheet DIAGNOSTICS

How this works – Output data from Software




# Calculations

# Generating the correct data output names


level	Zone Name	floor area m²	deta temp (deg F)	Delta T (Deg K)	Peak cooling load (kW)	Peak Heating Load (kW)	Peak load (kW)	Maximum flow rate for 20F (m³/s)	Baseline system	AHU name	W/m²	Average W/m² for the system	Does this zone differ by 31.2W/m²? By how much?	New AHU names	New Baseline System Numbers	For Simulation Diagnostics Zone temperature variable name	For Simulation Diagnostics Zone temperature variable name	Remove duplicates, (for the calculation s)
04	04 Archive	14	20	11.1	-	0.09	0.1	0.01	4	04 Archive	7	7 n	04 Archive	4	04 Archive:Zone Air Temperature [C](hourly)	04 Archive_zoneTemp	AHU00	
04	04 AV	7	20	11.1	0.25	0.13	0.3	0.02	8	AHU04	34	67 n	AHU04	8	04 AV:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU01	
04	04 CopyRoom1	10	20	11.1	0.36	0.23	0.4	0.03	8	AHU04	36	67 n	AHU04	8	04 CopyRoom1:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU02	
04	04 CopyRoom2	8	20	11.1	0.31	0.24	0.3	0.02	8	AHU04	38	67 n	AHU04	8	04 CopyRoom2:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU03	
04	04 Corridor1	18	20	11.1	-	0.02	0.0	0.00	4	04 Corridor1	1	1 n	04 Corridor1	4	04 Corridor1:Zone Air Temperature [C](hourly)	04 Corridor1_zoneTemp	AHU04	
04	04 Corridor2	74	20	11.1	-	0.97	1.0	0.07	4	04 Corridor2	13	13 n	04 Corridor2	4	04 Corridor2:Zone Air Temperature [C](hourly)	04 Corridor2_zoneTemp	AHU05	
04	04 Corridor3	55	20	11.1	-	0.34	0.3	0.03	4	04 Corridor3	6	6 n	04 Corridor3	4	04 Corridor3:Zone Air Temperature [C](hourly)	04 Corridor3_zoneTemp	AHU06	
04	04 Corridor4	24	20	11.1	-	0.08	0.1	0.01	4	04 Corridor4	3	3 n	04 Corridor4	4	04 Corridor4:Zone Air Temperature [C](hourly)	04 Corridor4_zoneTemp	AHU07	
04	04 MeetingRoom1	19	20	11.1	1.44	0.51	1.4	0.11	8	AHU04	74	67 n	AHU04	8	04 MeetingRoom1:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU08	
04	04 MeetingRoom2	15	20	11.1	1.06	0.44	1.1	0.08	8	AHU04	68	67 n	AHU04	8	04 MeetingRoom2:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU001	
04	04 MeetingRoom3	60	20	11.1	5.61	1.94	5.6	0.42	8	AHU04	94	67 n	AHU04	8	04 MeetingRoom3:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	AHU002	
04	04 MeetingRoom4	7	20	11.1	0.54	0.15	0.5	0.04	8	AHU04	74	67 n	AHU04	8	04 MeetingRoom4:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.00_ITRoom	
04	04 Office1	54	20	11.1	4.46	1.83	4.5	0.33	8	AHU04	83	67 n	AHU04	8	04 Office1:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.00_KitchenNorth	
04	04 Office2	35	20	11.1	3.02	1.34	3.0	0.23	8	AHU04	86	67 n	AHU04	8	04 Office2:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.01_KitchenNorth	
04	04 Office3	44	20	11.1	3.71	1.68	3.7	0.28	8	AHU04	84	67 n	AHU04	8	04 Office3:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.02_ITRoom	
04	04 Office4	37	20	11.1	2.39	1.31	2.4	0.18	8	AHU04	65	67 n	AHU04	8	04 Office4:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.02_KitchenNorth	
04	04 Office5	11	20	11.1	0.82	0.66	0.8	0.06	8	AHU04	76	67 n	AHU04	8	04 Office5:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.03_ITRoom	
04	04 Office6	66	20	11.1	4.05	1.90	4.1	0.30	8	AHU04	61	67 n	AHU04	8	04 Office6:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.03_KitchenNorth	
04	04 OpenOffice1	182	20	11.1	16.30	5.95	16.3	1.22	8	AHU04	90	67 n	AHU04	8	04 OpenOffice1:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.04_ITRoom	
04	04 OpenOffice2	77	20	11.1	6.29	2.34	6.3	0.47	8	AHU04	82	67 n	AHU04	8	04 OpenOffice2:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.04_KitchenNorth	
04	04 OpenOffice3	54	20	11.1	4.43	1.66	4.4	0.33	8	AHU04	82	67 n	AHU04	8	04 OpenOffice3:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.05_ITRoom	
04	04 OpenOffice4	118	20	11.1	10.61	3.86	10.6	0.80	8	AHU04	90	67 n	AHU04	8	04 OpenOffice4:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.05_KitchenNorth	
04	04 PhoneBooth1	5	20	11.1	0.20	0.13	0.2	0.02	8	AHU04	41	67 n	AHU04	8	04 PhoneBooth1:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.06_ITRoom	
04	04 PhoneBooth2	5	20	11.1	0.21	0.17	0.2	0.02	8	AHU04	45	67 n	AHU04	8	04 PhoneBooth2:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.06_KitchenNorth	
04	04 Shower	6	20	11.1	0.20	0.24	0.2	0.02	8	AHU04	39	67 n	AHU04	8	04 Shower:Zone Air Temperature [C](hourly)	AHU04_zoneTemp	EB.07_ConferenceNo	
		0													0:Zone Air Temperature [C](hourly)	_zoneTemp	EB.07_ITRoom	
04	04 Storage3	15	20	11.1	-	0.14	0.1	0.01	4	04 Storage3	9	9 n	04 Storage3	4	04 Storage3:Zone Air Temperature [C](hourly)	04 Storage3_zoneTemp	EB.07_Kitchen	
04	04 TeaRoom	31	20	11.1	0.75	0.44	0.8	0.06	4	04 TeaRoom	24	24 n	04 TeaRoom	4	04 TeaRoom:Zone Air Temperature [C](hourly)	04 TeaRoom_zoneTemp	EB.07_OpenOfficeNo	
															Zone Air Temperature [C](timestep)	_zoneTemp	EB.07_OpenOfficeNo	
															Zone Air Temperature [C](timestep)	_zoneTemp	EB.07_OpenOfficeSou	
															Zone Air Temperature [C](timestep)	_zoneTemp	EB.U01_EntranceEast	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.00_EntranceSout	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.01_ITRoom	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.01_OfficeSouthw	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.02_ITRoom	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.02_OfficeSouthw	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.02_ReceptionBric	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.03_ITRoom	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.03_OfficeSouthw	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.03_ReceptionBric	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.04_ITRoom	
															Zone Air Temperature [C](timestep)	_zoneTemp	NB.04_OfficeSouthw	

How this works – Scripting what data needs to be called




How the works – Data analysis and quality control


# Energy Component Diagram





## AHU Analysis – VAV reheat example



System to Zone Temperature : AHU-1  
Summer Operation - 11 Jul - 5pm




# AHU Analysis – Simultaneous Heating and Cooling



# AHU Analysis – Heat Exchanger and Cooling Coil

## Statistics and Heating Cooling Analysis (SI)

	Hours in the year these conditions apply
Heat Exchanger exchanging heat	2,680
Heat Exchanger exchanging cool	733
AHU Heating Coil ON	-
AHU Cooling Coil ON	3,388
AHU heating and cooling on at the same time	-
Heat Exchanger exchanging Heat and Cooling Coil ON	2,655
Heat Exchanger exchanging Cool and heating Coil ON	-
Total number of hours system is on	3,413
Hours heat exchanger should be bypassed in the summer	-



## AHU Analysis – Heat Exchanger and Cooling Coil





## Air Handling Unit Diagnostics

AHU? **AHU1**  
 Month **March**  
 Day **26**  
 Time **12 noon**  
 Lookup **March 26, 12 noon**  
 Occupied or Unoccupied **Office hours**



**Instructions:**  
 1) Add the name of the AHU that you would like to see the diagnostics through  
 2) Add the month fully written out  
 3) Add the date  
 4) Finally add the time with am or pm directly afterwards  
 The green band on the graph indicates the comfortable temperature in the space, this will need to be adjusted from project to project

AHU1



Data | Data Analysis | OD AHU | OD AHU (IP) | **AHU Graph** | Statistics | Sheet2 | Sheet6 ...

# AHU and Controls Analysis Tool



August 25<sup>th</sup> 2pm

# AHU Analysis – Case study

- Unclear controls can easily lead to simultaneous heating and cooling.
- Heat exchangers can be added to systems thinking they will save energy but in fact cause the system to use more energy.
- Lack of analysis, misunderstanding how a systems actually works and business as usual leads to poor performance of building systems.
- Energy modellers can model and give extremely valuable feedback on controls for the building saving thousands of pounds of operational energy costs.

## AHU and Controls Modelling and Analysis

---

PROBLEM 2: Input errors and misunderstanding outputs leads to poor results, lack of confidence in modelling and, at worse, incorrect analysis and advice to the client

SOLUTION 2: Simulation diagnostics!

Annie Marston Ph.D., BEMP, LEED AP  
Building Performance Analyst

**SIM<sup>2</sup>** amarston@sim2inc.com  
+44 (0) 7985 874 932



Don't compromise -- simulate

— SIM<sup>2</sup> —