

CIBSE BSG

Designing for Better Indoor Environmental Quality Buildings:

A Mixed-Mode Office Building with Exemplary IEQ

Ben Richardson MEng Senior Sustainability Consultant 11 June 2013

Introduction




Background
Exposure to Air Pollutants
Air Quality Analysis for a Mixed-Mode Building
Summary

Background - Case study



- Office development in Kings Cross
- Floor area: 1,000,000 ft²
- 10 floors
- Client willing to push boundaries



Background - Client Targets



"Optimising capital and innovation to create a highly flexible, productive and healthy working environment, with low long-term operating costs and the smallest possible environmental impact"

"Environmental performance beyond anything else happening today or planned for tomorrow"



'Aim: Outstanding'

- Representative of top 1% of nondomestic building stock
- > 85% total credits
- > 40% better than Part L as a minimum standard



'Aim: Platinum'

- > 80% total credits
- Aiming for ~28% better than ASHRAE
 90.1-2007 energy standard

Energy v's Indoor Environmental Quality

V's



Mixed-mode




Air Quality

Acoustics

Other issues: Control scheme, Air tightness, Architectural considerations, Facade access, Maintenance, Cost and Complexity, etc.





Air Quality - Exposure to Air Pollutants





(one without the other is meaningless)

| Pollutant | Concentration Limit | Measured as |
|---|---------------------------------|----------------|
| Nitrogen Dioxide (NO ₂) | 40 μg/m ³ | Annual average |
| | 200 μg/m ³ | 1 hour average |
| Particles (PM ₁₀) | 40 μg/m ³ | Annual average |
| | 50 μg/m ³ | 24 hour mean |
| Ultra-Fine Particles (PM _{2.5}) | 25 μg/m ³ | Annual average |
| Sulphur Dioxide (SO ₂) | 125 μg/m³ three times per annum | 24 hour mean |

NO₂ Standards



| Standard | Limit (μg/m³) | Measurement period |
|--------------------------------|--|---|
| | 40 | Annual average (long-term) |
| UK Air Quality Standard | 200 (not to be exceeded more than 18 times per year) | Hourly average (short-term) |
| European Union Standard | as above | |
| World Health Organisation | 40 | Annual average (long-term) |
| | 200 | 98 th percentile averaged over 3 years |
| California Ambient Air Quality | 60 | Annual average (long-term) |
| Standard | 360 | Hourly average (short-term) |
| Historical Client Operational | 40 | Annual average (long-term) |
| Performance Requirement (OPR) | 200 | Hourly average (short-term) |

PM_{10} Standards



| Standard | Limit (μg/m³) | Measurement period |
|---|---|------------------------------|
| UK Air Quality Standard | 40 | Annual average (long-term) |
| | 50 (not to be exceeded more than 35 times per year) | 24-hour average (short-term) |
| European Union Standard | as above | |
| World Health Organisation | 20 | Annual average (long-term) |
| | 50 | 24-hour average (short-term) |
| California Ambient Air Quality | 20 | Annual average (long-term) |
| Standard | 50 | 24-hour average (short-term) |
| Historical Client Operational Performance Requirement (OPR) | 20 | Annual average (long-term) |
| | 50 | 24-hour average (short-term) |

PM_{2.5} Standards




| Standard | Limit (μg/m³) | Measurement period |
|---|---------------|---|
| UK Air Quality Standard | 25 | Annual average (long-term) to be achieved by 2015 |
| World Health Organisation | 10 | Annual average (long-term) |
| | 25 | 24-hour average (short-term) |
| California Ambient Air Quality Standard | 12 | Annual average (long-term) |
| Historical Client Operational Performance Requirement (OPR) | 10 | Annual average (long-term) |
| | 25 | 24-hour average (short-term) |

Exposure to Air Pollutants





Approx 30% of our annual exposure is at work



for roughly 1/3 of that time the windows will be open....

....for the other 2/3 of that time the air quality will be very highly controlled

Filtration




CitySorb: 90% removal efficiency for NO₂

95% removal efficiency of PM₁₀


















Nearby Monitoring Station






Onsite Monitoring













Monitoring Results – NO2





Monitoring Results – SO2






| | SO2 |
|----------|---------------|
| | Average |
| Location | $(\mu g/m^3)$ |
| 1 | 1.5 |
| 2 | 1.2 |
| 3 | 1.1 |
| 4 | 1.2 |
| 5 | 1.2 |
| 6 | 1.1 |
| 7 | 1.0 |
| 8 | 4.1 |
| 9 | 1.7 |
| 10 | 2.2 |
| 11 | 1.2 |
| 12 | 1.2 |
| 13 | 1.2 |
| 14 | 1.7 |
| 15 | 1.3 |
| 16 | 1.2 |
| Average: | 1.5 |

| | Oct-12 | Nov-12 | Dec-12 | Jan-13 | AQLV |
|--------------|--------|--------|--------|--------|------|
| 15-min Peak | 14 | 18 | 19 | 33 | 266 |
| 1-hour Peak | 8 | 11 | 11 | 20 | 350 |
| 24-hour Peak | 3 | 4 | 4 | 7 | 125 |

Monitoring Results – PM10








Can we achieve good air quality levels within a mixed-mode building in central London?

Air Quality Analysis for a Mixed-Mode Building











Temperature














Air Quality Analysis for a Mixed-Mode Building











 NO_2








Air Quality Analysis for a Mixed-Mode Building



All Parameters (Temperature + PM_{10} + $PM_{2.5}$ + NO_2)



Spreadsheet analysis...



| | Estimated Annual Concentration (µg/m³) | UK Limit (μg/m³) |
|-------------------|--|---------------------|
| NO ₂ | 29 | 40 |
| PM ₁₀ | 9 | 40 |
| PM _{2.5} | 8 | 25 |



Good air quality levels *are* achievable within a mixed-mode building in central London... ...in theory!

But is the concept of a mixed-mode building lost?

To be continued....

